

### **Provisions**

You must describe in detail the provision(s) of the existing permit that you wish to modify. You may either type the details into this application or upload a file containing the information.

The current freeboard provision for the effluent storage tank at Dovetail Energy is 2 ft (a total working volume of 4,549,742 gallons). This provision needs adjusted to the NRCS 313 freeboard requirement of 1' which OEPA has indicated is a suitable standard. The freeboard requirement will be 1ft with 19ft of effluent storage (a total working volume of 5,402,446). In addition to the freeboard requirement change, Dovetail will report storage tank levels on a monthly basis.

### **Reasons**

You must describe in detail the reasons you are seeking to modify the identified provisions of the existing permit. Refer to OAC 3745-33-04(D) for acceptable grounds for modifying a permit. You may either type the details into this application or upload a file containing the information.

Modifying the NPDES will accurately reflect as built condition of the existing storage tank acknowledge 5,402,446 gallons of working capacity based on a 1' free board requirement. Finally, reporting the freeboard monthly with the eDMR will ease communication with Ohio EPA.

### **Modification Details**

You must describe the requested modification in sufficient detail to allow Ohio EPA to process the request. You may either type the details into this application or upload a file containing the information.

Modify the current Dovetail Energy NPDES to reflect the minimum freeboard requirements of 1ft outlined in NRCS 313 Conservation Practice Standard: Waste Storage Facility and the storage volume of 19ft of material based on the appropriate as built for the storage tank. In addition, add a parameter onto the monthly eDMR that reports freeboard remaining for the storage tank.